

2023 WATER QUALITY REPORT

FOR

LENOX WATER SUPPLY

Este informe contiene informacion muy importante sobre su agua bebar. Traduzcalo o hable con alguien que lo entienda bien.
This report contains important information regarding the water quality in our water system. The source of our water is surface water. All of the water is purchased. Purchased water comes from Creston Water Supply. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	31.00 (11 - 52)	3/31/2023	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	LRAA	20.00 (10 -30)	3/31/2023	No	By-products of drinking water disinfection
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	LRAA	20.00 (7 – 33)	3/31/2023	No	By-products of drinking water disinfection
Copper (ppm)	AL=1.3 (1.3)	90th	0.0848 (0.0121 - 0.0919)	2021	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90th	0.00 (ND - 2)	2021	No	Corrosion of household plumbing systems; erosion of natural deposits
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.8 (1.51 – 3.11)	9/30/2023	No	Water additive used to control microbes

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LENOX WATER SUPPLY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SOURCE WATER ASSESSMENT INFORMATION

This water supply obtains some or all of its water from another public water supply. It is a consecutive water supply, where an originating parent supply provides drinking water to one or more downstream supplies.

Original Supply ID	Original Supply Name
IA8816089	Creston Water Supply

OTHER INFORMATION

Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique. "In accordance with Federal Law and US Department of Agriculture policy, this institution (may substitute name of recipient) is prohibited from discriminating on the basis of race, color, national origin, age, disability, and where applicable, sex, marital status, familial status, parental status, religion, sexual orientation, genetic information, political beliefs, reprisal, or because all or part of an individual's income is derived from any public assistance program. (Not all prohibited bases apply to all programs.)

To file a complaint of discrimination, write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, SW, Washington, DC 20250-9410 or call 800-795-3272 (voice) or (202)720-6382 (TDD). USDA is an equal opportunity lender, provider and employer."

The Lenox Water Supply had no violations for the 2023 calendar year.

CONTACT INFORMATION

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact LENOX WATER SUPPLY at 641-333-2550.

Decisions are made at the utility board meetings held on the 2nd Thursday of each month at 6:30 am at City Hall and are open to the public.

PURCHASED WATER INFORMATION

Our water system purchases water from the system(s) shown below. Their water quality is as follows:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)		Yes/No	
8816089 - CRESTON WATER SUPPLY						
01 - TWELVE MILE LAKE @ WATER PLANT						
Fluoride (ppm)	4 (4)	SGL	1.17 (0.57 – 1.17)	12/22/2023	No	Water additive which promotes strong teeth; Erosion of natural Deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.13	11/12/2019	No	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Arsenic (ppb)	10 (0)	SGL	2.00	11/12/2019	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Nitrate [as N] (ppm)	10 (10)	SGL	0.26	2023	No	Runoff from fertilizer use; Leaching from septic tanks; Sewage; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	17	09/18/2023	No	Erosion of natural deposits; Added to water during treatment process
PBFS (ppb)	NA	SGL	0.0051	10/2/2023	No	Factory and Agricultural runoff
02 - THREE MILE LAKE AFTR TRTMT @ WTR PLT						
Fluoride (ppm)	4 (4)	SGL	1.11 (0.71 – 1.11)	04/12/2023	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Arsenic (ppm)	10 (0)	SGL	0.10	04/12/2022	No	Erosion of natural deposits; Runoff form orchards; Runoff from glass and electronic production wastes
Barium (ppm)	2 (2)	SGL	0.09	04/12/2022	No	Discharge of drilling wastes; Discharge form metal refineries; Erosion of natural deposits
Nitrate [as N] (ppm)	10 (10)	SGL	0.55	2023	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Dalapon (ppb)	200 (200)	SGL	0.40	04/04/2022	No	Runoff from herbicide used on rights of way
Atrazine (ppb)	3 (3)	RRA	ND	09/30/2023	No	Runoff from herbicide used on rights of way
Total Organic Carbon TOC ppm	NA (N/A)	TT	32.14 (32.14 – 72.84)	06/05/2023	No	Naturally present in the environment.
Turbidity (NTU)	N/A (N/A)	TT	0.739 99.82% below 0.1	08/02/2023	No	Soil runoff